

Si No	Bidding Documents Reference(S) (Section number /page)	Content of RFP Requiring	points of Clarifications	IGL Comment
1	SECTION V SCOPE OF WORK & TECHNICAL SPECIFICATION/Pg 66	Sr. No 5. constructional design features:- a) Dedicated and physically separated cable termination points (from other internal circuitry part of UPS) for termination of input cables, output cables & battery cable.	for low rated UPS input cables are sealed and soldered at main PCB and output points are indian socket, So Kinldy remove the point "Dedicated and physically separated cable termination "	Tender condition prevails.
2	SECTION V SCOPE OF WORK & TECHNICAL SPECIFICATION/Pg 67	Sr.no 10. AC Output Voltage:- b) Permissible % Voltage Variation: Non-fluctuating, Plus or Minus 1.0 % or better from full load to no load.	Isolation transformer is used at output side due to this the voltage regulation goes to $\pm 2\%$, as per industrial practice. Request to ammend it as +/-2%	Tender condition prevails.
3	SECTION V SCOPE OF WORK & TECHNICAL SPECIFICATION/Pg 67	Sr. No-13 Harmonic Distortion: Shall be less than 3 % for linear loads and less than 5 % for nonlinear loads.	Shall be less than 6 % for nonlinear loads. Which is common in industrial practice as Isolation is connected at output. Request to ammend as less than 6 % for nonlinear loads.	Tender condition prevails.
4	SECTION V SCOPE OF WORK & TECHNICAL SPECIFICATION/Pg 67	Sr. No 27- Nameplate of UPS should be of anodized aluminum plate with all ratings along with UPS serial no. In-put voltage range, DC voltage etc.	Name Plate along with serial number comes with Paper sticker which is common in industrial practice. Reques for Paper sticker name plate also.	Tender condition prevails.
5	Section IV SCC Clause 6.0 CPBG	6.0 CONTRACT CUM EQUIPMENT PERFORMANCE BANK GUARANTEE	Kindly note that Successful bidder need to submit "Contract Cum Equipment Bank Guarantee " upon successful award of Contract . The Said tender is for Supply of UPS along with CAMC Service for 5 Year (1 Year During Warranty , 4 Year CAMC after Completion of Warranty Period). As Both ,Supply and Contract Period (4 Year CAMC) is separate Parts with Separate invoicing and Payment Process, We Request you to keep "Performance Bank guarantee " Separate for "Supply" and "Contract" or our Principle Capital is blocked for 5-6 Years and increase our finance cost /Cost of operation.	Tender condition prevails. Pl. refer Clause 6.0 of SCC.