



CORRIGENDUM # 2

SUPPLY OF FIRE FIGHTING DRY CHEMICAL POWDER
TENDER NO. IGL/ET2/CP/CM17855 dated 16.01.2024

Tender Ref. No.: IGL/ET2/CP/CM17855

Tender date: 16.01.2024

Owner: Indraprastha Gas Ltd.

Corrigendum Date: 01.02.2024

Sl. No.	Tender Page No.	Clause/ Para/ Section	Description	Amendment/ Addition/ Modification/ Deletion	
1	60 of 83	Point no. 3 of Technical Specification	shall have minimum application density when tested to extinguish a 20B (UL 711)	Amendment	May be read as "minimum application density shall not be more than 0.65kg/m ² "
2	60 of 83	Point no. 9 c of Technical Specification	Manufacturer of the product should have In-House NABL accredited testing facility for testing of quality of Dry Chemical powder	Amendment	May be read as "In addition to NABL accredited testing facility, Govt. approved testing facility shall also be considered".

Note:

1. All other terms & conditions of tender document remain unaltered.
2. Bidders are requested to visit IGL website <https://www.iglonline.net> / IGL's tendering website <https://petroleum.euniwizarde.com> regularly for further announcement.