



**CORRIGENDUM # 3**

**SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING**

**TENDER NO. IGL/ET2/CP/CP17435 dated 28.04.2023**


Tender Ref. No.: IGL/ET2/CP/CP17435

Tender date: 28.04.2023

Owner: Indraprastha Gas Ltd.

Corrigendum Date: 26.05.2023

Sl. No.	Tender Page No.	Clause/ Para/ Section	Description	Amendment / Addition / Deletion	
1	7 of 96	Cl. No. 5.0 under Sec-I (IFB)	Availability of tender document on website(s)	Amendment	From 28.04.2023 to 02.06.2023
2	7 of 96	Cl. No. 5.0 under Sec-I (IFB)	Bid submission due date and time	Amendment	02.06.2023 till 1430 hrs IST
3	7 of 96	Cl. No. 5.0 under Sec-I (IFB)	Techno-commercial bid opening date and time	Amendment	02.06.2023 at 1500 hrs IST
4	63 of 96	Cl. No. 1.0 under Sec-V (SOW)	REGULATOR SYSTEM Vendor shall take care during designing the skid, so that, in failure of any component of the stream changeover system, shall not result in over-speeding of RPD meter and velocity in the RPD meter stream shall not cross the limit of 20 m/s in any case.	Addition	In failure of any component of the stream changeover system, the velocity in the RPD meter stream shall not cross 40m/s.
5	65 of 96	Cl. No. 6.0 under Sec-V (SOW)	TECHNICAL REQUIREMENTS Regulators for downstream regulation shall be provided with integral relief valve.	Deletion	This Tender Clause stands deleted.
6		General	Data Sheet for Regulator and SSV	Addition	Data Sheet Enclosed
7	72 of 96	Sec-VI (SOR)	Approved Vendor List for Instrument fitting and Piping Material	Addition	List Enclosed
8		General	Vendor List for Regulator, SSV, tubing and fitting	Addition	List Enclosed

		CORRIGENDUM # 3		Tender Ref. No.: IGL/ET2/CP/CP17435	
		SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING  TENDER NO. IGL/ET2/CP/CP17435 dated 28.04.2023		Tender date: 28.04.2023	
				Owner: Indraprastha Gas Ltd.	
				Corrigendum Date: 26.05.2023	
Sl. No.	Tender Page No.	Clause/ Para/ Section	Description	Amendment / Addition / Deletion	
9	67 of 96	Cl. No. 8.2 under Sec-V (SOW)	Functional Testing Each regulator shall be accurately calibrated and tested by the Manufacturer at the normal working conditions specified in the attached data sheet. All test equipment used for testing shall have traceability to national standards.	Addition	Data sheet enclosed
10	69 of 96	Cl. No. 11.1(e) under Sec-V (SOW)	Weights & Measures Approval Certificate	Deletion	This Tender Clause stands deleted

Note:

1. All other terms & conditions of tender document remain unaltered.
2. Bidders are requested to visit IGL website <https://www.iglonline.net> / IGL's tendering website <https://petroleum.euniwizarde.com> regularly for further announcement.
3. This Corrigendum shall be a part of the Tender Document and must be submitted duly signed and stamped with the bid as a token of acceptance.