



INDRAPRASTHA GAS LIMITED
IGL Bhawan, 4, Community Center,
Sector 9, R.K.Puram, New Delhi-110022
Email: ankush.jain@igl.co.in ; gaurav.agrawal1@igl.co.in; dnagar@igl.co.in
TelePhone: +91 (11) 46074-651, 657, 659

TENDER DOCUMENT NO. IGL/ET2/CP/CP19030
Procurement of Required Components and Restoration of Flow Signal Mode at IGL Odorizing Units

CORRIGENDUM No. - I

Sr. No.	Section no.	Clause No.	Page No.	Description	Amendment / Additional/ Modification / Deletion	
1	Section I of IFB	Clause no. 3.2	7	The supply shall be delivered at the designated store/site within 10 weeks from the date of first intimation by IGL. In case of delay, a penalty of ₹500/- per day shall be imposed.	Modification	May be read as: Subsequent to supply, installation, integration, testing and commissioning of these system shall be completed in all respect in 90 days for all sites from the date of first intimation from IGL, else penalty of Rs. 500/- per site per day shall be imposed.
2	Section V of SOW	Clause no. 4.0	68	4.0 RESPONSIBILITY FOR COMPATIBILITY Since the work involves integration with existing Elster enCore FC1 and Emerson/FloBoss Flow Computer systems/Other, the contractor shall verify the compatibility of the supplied Analog Output Cards/Modules with the existing installed systems before supply. The contractor shall be responsible for successful integration and commissioning of the supplied cards/modules and associated accessories. Any additional effort required for configuration, wiring correction or integration within the contractor's defined scope shall be carried by bidder out without additional financial implication to IGL.	Modification	May be read as: 4.0 RESPONSIBILITY FOR COMPATIBILITY Since the work involves integration with existing Elster enCore FC1 and Emerson/FloBoss Flow Computer systems/Other, the contractor shall verify the compatibility of the supplied Analog Output Cards/Modules with the existing installed systems before supply. The contractor shall be responsible for successful integration and commissioning of the supplied cards/modules and associated accessories. Bidder has to take the flow signal from the flow computer after supply, Installation, testing & commissioning of all the SOR items to the odorization PLC/Automation system in order to make the odorization system must work in auto/flow mode. Bidder has to take the required flow data & analyses before completing the activity in order to ensure that the odorization system works proportional to the flow subsequently, contractor has to provide/validate the flow mode operation shall be reflected to the IGL SCADA system, if any additional arrangement to be made shall be in the contractor scope. Any additional effort required for configuration, wiring correction or integration within the contractor's defined scope shall be carried by bidder out without additional financial implication to IGL.

- Note:
1. Bidders are requested to visit IGL website / IGL's tendering website <https://igl.ewizard.in> regularly for further announcement.
 2. All other terms & conditions of tender document remain unaltered.
 3. Please submit the signed and stamped copy of this corrigendum along with your offer.