



REPLY TO BIDDER'S PRE-BID QUERIES

Annual Rate Contract for Calibration of Gas & Flame Detectors installed in CNG Compressors

BID DOCUMENT NO. IGL/ET2/CP/CC18441

Owner: INDRAPRASTHA GAS LTD

Sl No	Page No.	Clause No. & Description	Tender Requirement	Bidder's Query	IGL's Reply
1	60	SOW- xx	All material, manpower, transportation, supervision, reference test and calibration equipment, tools, tackles, test fluid, gas cylinders, nitrogen, test manifold and contraptions, power, water, logistics and necessary harness etc. shall be supplied by you for carrying out the scope of work	As power is in our scope where shall we use it as GD&FD are already powered online?	Tender Condition prevail
2	60	SOW- xxi	However, if IGL feels that recalibration of the instruments and devices are not possible without replacement of specific spare parts in the same, the said parts would be supplied from IGL stock. Installation, wiring and calibration/ checking etc will be executed by you without any cost to IGL	If any Software updation is required for GD&FD shall IGL provide?	Tender Condition prevail
3	60	SOW- xxiv	You shall be normally working for the job during IGL working hours (9 am to 6 pm) basis including Sundays and holidays. In special cases you may be asked to extend your working hours & schedule	How many stations shall IGL provide per day for Calibration?	Tender Condition prevail
4	60	SOW- xxiv	You shall be normally working for the job during IGL working hours (9 am to 6 pm) basis including Sundays and holidays. In special cases you may be asked to extend your working hours & schedule	Is there any time limit for completion job as per Schedule?	Tender Condition prevail
5	60	SOW- xxvi	Quantity & make of detectors may vary during calibration	Please Specify Make & model of GD& FD station wise as required for SOR.	GD:Ametronics (GT4000), Crowcon(nimbus), Detronics (IR700, PIR9400), ESP(mS40EE-M-11), GASTRon(GIR3000), Honeywell (XCD, Optima+), MEI, Sensitron(smart S), Netsafety(SC311A)
6					FD:Ametronics (FLD3300,UVIR), Omni Guard(860-00100), Detronics (X2200A), ESP(UV/IR, Max3V), Honeywell (SS4), Netsafety(UV/RS-A), Pyrotech(20/21),MSA(5UVIR), Sharpeye(20/21),Rose mount(UV/IR)
7	60	SOW- xx	All material, manpower, transportation, supervision, reference test and calibration equipment, tools, tackles, test fluid, gas cylinders, nitrogen, test manifold and contraptions, power, water, logistics and necessary harness etc. shall be supplied by you for carrying out the scope of work	List of make and model for GD	GD:Ametronics (GT4000), Crowcon(nimbus), Detronics (IR700, PIR9400), ESP(mS40EE-M-11), GASTRon(GIR3000), Honeywell (XCD, Optima+), MEI, Sensitron(smart S), Netsafety(SC311A)
8				List of make and model for FD	FD:Ametronics (FLD3300,UVIR), Omni Guard(860-00100), Detronics (X2200A), ESP(UV/IR, Max3V), Honeywell (SS4), Netsafety(UV/RS-A),Pluto(UV) Pyrotech(20/21),MSA(5UVIR), Sharpeye(20/21),Rose mount(UV/IR)
9		SOW- xxi		Type of sensors for LEL.	Methane (90-95%)and other Hydrocarbon are used (IR, Catalytic and IR, UV, UVIR3,5)

**REPLY TO BIDDER'S PRE-BID QUERIES****Annual Rate Contract for Calibration of Gas & Flame Detectors installed in CNG Compressors****BID DOCUMENT NO. IGL/ET2/CP/CC18441****Owner: INDRAPRASTHA GAS LTD**

Sl No	Page No.	Clause No. & Description	Tender Requirement	Bidder's Query	IGL's Reply
10		SOW- xxiv		Site location and its details	Tender Condition prevail