



REPLY TO BIDDER'S QUERIES

SUPPLY OF CS FITTINGS, FLANGES, VALVES, INSULATING JOINTS & OTHER MISC. ITEMS

TENDER DOCUMENT NO. IGL/ET2/CP/CP18455, Dated 09.06.2025

Owner: Indraprastha Gas Ltd.

Pre-bid meeting: 17.06.2025

Date: 27.06.2025

Sl. No.	Clause No./ Spec. No.	Page No.	Description	Bidder's Query/Clarification	IGL Reply
Techno-Commercial					
11	Technical Volume II of II	66 of 286	Valves	In MR of valves mention datasheet No. 18455-019-PP-DS-2002A & 18455-019-PP-DS-2002B is not available.	Kindly read 18455-019-PP-DS-2002A & 18455-019-PP-DS-2002B as 18455-000-PP-DS-2002A & 18455-000-PP-DS-2002B respectively
12	Technical Volume II of II		Valves	In inspection and test plan for ball valve DOC NO: IGL-ITP-PP-2007 requirement is 3.1 certification, However as per given datasheet (18455-000-PP-DS-2002A) mention it's 3.2 certification.	"Tender conditions prevails " 3.2 Certification is required.
13	Technical Volume II of II		Valves	In standard specification for assorted valves (Doc No.: IGL-SS-PP-2504) sub clause No.3.19.7 requirement for Ball valves 4" & Below Floating type and 6" & Above Trunnion Type, However as per given datasheet (18455-000-PP-DS-2002A) requirement is Trunnion from 2" & Above.	"Tender conditions prevails" Data sheet to be followed, all valves size 2" and above shall be trunnion mounted.
14	Technical Volume II of II		Valves	In standard specification for assorted valves (Doc No.: IGL-SS-PP-2504) sub clause No.6.1 requirement for radio graphically examined is upto 400MM (16") in 300# rating NIL, However as per given datasheet (18455-000-PP-DS-2002A) requirement is 100% Radiographic Examination.	"Tender conditions prevails " 100% radiographic examination is required