



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17435

SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING

S.No.	Page	Section	Description	Bidder Queries	IGL Replies
1	63 of 96	SOW 1.0. REGULATOR SYSTEM	Vendor shall take care during designing the skid, so that, in failure of any component of the stream changeover system, shall not result in over-speeding of RPD meter and velocity in the RPD meter stream shall not cross the limit of 20 m/s in any case.	Velocity is also depends on the Line Size and various factors, as we are only supplying Regulator and SSV we will not be able to maintain the velocity at RPD meter.	In failure of any component of the stream changeover system ,the velocity in the RPD meter stream shall not cross 40m/s. Refer Corrigendum-3
2	63 of 96	SOW 1.0. REGULATOR SYSTEM	It is Vendor's responsibility to design the system full proof and if any problem arises in operation of the system, vendor shall resolve it without any cost implication.	As the scope is for Supply of Loose regulator and SSV with it's accessories only, so supplier will not be responsible for design the system full proof and Operation of the system. Supplier will be responsible for the supplied item and it's Operation only.	Supplier will be responsible for the supplied items and it's succesful operation and performance under client system. Tender Condition Prevails
3	65 of 96	SOW 6.0. TECHNICAL REQUIREMENTS	Regulators for downstream regulation shall be provided with integral relief valve.	As there are regulators 300# for FRS application, hope this clause is Not applicable for the said tender for selection of regulator.	This Tender Clause stands deleted. Refer Corrigendum-3
4	72 of 96	SOR	There are 13 Items as per SOR	We request IGL to provide address of Skid installed in these 13Items.	Items shall be supplied by the succesful bidders to IGL stores/site in Delhi/NCR as per clients requirement which shall be conveyed to succesful bidders at the time of award of PO. Tender Condition Prevails
5		General	Regulator, SSV	Hope Supplier can Choose regulator and SSV size based on their Sizing calculation and no need to follow the SOR Regulator Flange dia provided as Size of Regulator and SSV.	Tender condition Prevails.
6		General	Limit Switch	We understand that Limit Switch for Slam Shut is not in vendor scope.	Limit Switch is the part of SSV Tender Condition Prevails
7		General	Regulator and SSV	Kindly provide datasheet for regulator and SSV.	Data Sheet Enclosed Refer Corrigendum-3
8	72 of 96	SOR	Regulator Length	Hope Regulator length provided in SOR is Face to Face of Exsisting regulator avaiable at site and the same is not including any upstream Pipe and downstream pipe, kindly cofirm per return.	Bidder Understanding is correct. Tender Condition Prevails
9	72 of 96	SOR	SS tubing with all fittings and ferrule set : 8 metres	We understand that vendor need to supply 8Meter tube along with required fittings for the particular SOR line item. We request IGL will provide existing tubing and connection details for all location as per SOR, to ensure proper fittings is selected by bidder.	Tender condition prevails
10	72 of 96	SOR	c) Regulator pilot	We understand the requirement is for Loose Pilot of Regulator quoted in that particular item.	Pilot is required as a spare part separately. Tender Condition Prevails
11	72 of 96	SOR	Service for Regulator Installation & commissioning	We understand the Service specified in SOR is only for Installation & Commissiong of Regulator and SSV with it's accessories which is supplied by Supplier under this contract, kindly confirm per return.	Bidders Understanding is correct (Regulator installation & commissioning should be done by vendor on client call basis till the proper functioning of commissioned part and satisfaction of Client). Tender Condition Prevails



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17435

SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING

S.No.	Page	Section	Description	Bidder Queries	IGL Replies
12	55 of 96	SCC 7.0 PRICE REDUCTION SCHEDULE (PRS)	7.4. In contract, the portion of the supply/contract completed in all respect shall not be considered for applying PRS, if delivered within the contractual delivery period. The remaining supply/services, which has been completed beyond the contractual period, shall attract PRS @½% for the value of the supply/service in respect of which default in delivery has taken place subject to maximum of 5%.	As there is no defined period for Service so we request IGL to remove Service from PRS clause.	Tender condition Prevails.
13	56 of 96	SCC 8.0 PENALTY	8.1 A penalty of Rs. 100/day reckoned from the date of intimation shall be deducted from the invoice if Installation and Commissioning of regulator is not carried out within the defined period.	Kindly provide the defined period. We request IGL to provide 15Days prior intimation for commissioning of supplied items and within the Commissioning period if supplier is not able to commission the same then penalty clause will be applicable for the particular site regulator which are not commissioned. Also Maximum Penalty will be 5% of the SOR rate for Installation and Commissioning Service for particular regulator.	Tender condition Prevails.
14	56 of 96	SCC 8.0 PENALTY	8.2 Max penalty shall be 50% of the SOR rate for Installation and Commissioning service.	8.2 Max penalty shall be 5% of the SOR rate for Installation and Commissioning service.	Tender condition Prevails.
15	56 of 96	SCC 10.0 DURATION OF CONTRACT	10.1 Delivery of material shall be completed in 02 lots with 10-month period between the lots and delivery period shall be 8-10 weeks from the date of intimation/PO. First lot tentative quantity shall be 75% ± 10% of the total SOR quantity. However, the quantity may vary as per actual business requirement.	We request IGL to accept 16Weeks delivery for supply portion from the date of P.O.	Tender condition Prevails.
16	56 of 96	SCC 10.0 DURATION OF CONTRACT	10.2 Completion period for Installation and Commissioning services shall be 1 year from the date of award of PO.	Prices quoted in SOR for Service will be valid for 1Year from the date of award of P.O. within that period IGL can provide commissioning request. We request IGL to provide 15Days prior intimation for commissioning of supplied items. We request IGL to Issue Gate pass and other entry permit for Commissioning incase of their Customer permises.	Tender condition Prevails.
17	72 of 96	SOR	Sensing Valve for Regulator	We understand sensing valve required for tubing at downstream of regulator will be IGL Scope. Also, please confirm size of sensing valve for us to select instrument connector accordingly	All Fittings supplied by vendors include sensing valve as well. Tender Condition Prevails.
18	72 of 96	SOR	Aproved Vendor List	Kindly approved Approved Vendor List we need to follow for Instrumetn fitting and Piping Material	List Enclosed. Refer Corrigendum-3
19	72 of 96	SOR	Spool piece (ring) of dia 3" with thickness 2":	we understand spool piece of given dia only we need to consider.	Tender Condition Prevails.



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17435

SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING

S.No.	Page	Section	Description	Bidder Queries	IGL Replies
20	72 of 96	SOR	Spool piece (ring) of dia 3" with thickness 2":	Please give clarity on spool thickness requirement which is mention in SOR description	Tender condition prevails (Required Regulator need to be fit in specified space itself or with the help of spool.)
21		General		We understand dismantling of exisisting regulator and slam shut valve will be under IGL scope.	Bidder's understanding is incorrect. Tender Condition prevails
22		General		We understand that Civil/ Base frame/ Earthing etc.. will not be under bidder scope. Bidder scope is only Supply, Installation and Commissioning of Supplied items only, kindly confirm per return.	Bidder understanding is correct Tender Condition Prevails.
23		Vendor List		As the major portion of supply is Regulator, SSV, tubing and fitting, We request IGL to provide vendor list for the same.	List Enclosed. Refer Corrigendum-3
24	7 of 96	Due Date	Bid submission due date and time: 12.05.2023 till 1430 hrs IST	Considering the Scope of work we request IGL to provide 21days extension from the date of pre bid reply.	Refer Corrigendum-3
25	32 of 96	GCC- 8.0 Confidentiality	Kindly refer entire clause	We request IGL to confirm obligation under this clause shall be valid for a period of 3 years from the date of receipt of the Information.	Tender Condition Prevails
26	32 of 96	GCC- 9. Contract Obligations	Kindly refer entire clause	we request IGL to delete line "Any change in layout due to site conditions or technological requirement shall be binding on the Contractor and no extra claim on this account shall be entertained." Any change in the scope shall be mutually agreed between the parties.	Tender Condition Prevails
27	33 of 96	GCC- 12. Patent Rights	Kindly refer entire clause	Clause 12 applies only while Customer does all the following: a) promptly tells supplier in writing that an Intellectual Property Claim has been threatened or filed; b) allows Supplier complete control of the defense and settlement of the claim; and c) gives all reasonable help and cooperation requested by Supplier for the defense.	Tender Condition Prevails
28	36 of 96	GCC- 21 Latent Defect	Kindly refer entire clause	We request IGL to delete the said clause.	Tender Condition Prevails
29	37 of 96	GCC 24 Fall Clause	Kindly refer entire clause	We request IGL to delete the said clause as the Tender is for Project order.	Tender Condition Prevails
30	55 of 96	GCC_ 29. Price Reduction Schedule(PRS) & clause 7 of SCC	Kindly refer entire clause	The Price Reduction Schedule shall be equivalent to 0.5% of value of delayed quantity of undelivered goods per week or part thereof of delay up to a maximum of 5% of the value of delayed quantity of undelivered material.	Tender Condition Prevails
31	40 of 96	31.0 OWNER MAY DETERMINE / TERMINATE CONTRACT 33.0 Termination for Owner's Convenience	Kindly refer entire clause	a) In case of cancellation/termination for convenience or default of the Owner, the Seller shall be entitled to recover the cancellation charges as given in note 1 below shall apply alongwith 10% Termination fee of the cancelled value from the Buyer. b) In case cancellation/termination for convenience, the buyer shall return all the Bank Guarantees and all the securities, if applicable (given by the seller to the buyer in terms of this agreement.) immediately after the termination to the seller.	Tender Condition Prevails
32	41 of 96	GCC- 34. Force Majeure	Kindly refer entire clause	We request IGL to add Epidemic/Pandemic and shortage of material affecting entire industry or region as Force majerue events	Tender Condition Prevails



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17435

SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING

S.No.	Page	Section	Description	Bidder Queries	IGL Replies
33	42 of 96	GCC- 36 Limitation of Liability	Kindly refer entire clause	<p>We request Limitation of liability clause without any exceptions. Please accept the clause with following changes:-</p> <p>Except in cases of wilful negligence or wilful misconduct, and in the case of infringement, the Supplier shall not be liable to the Purchaser, whether in contract, tort, or otherwise, for any indirect or consequential loss or damage, loss of use, loss of production, or loss of profits provided that this exclusion shall not apply to any obligation of the Supplier to pay Price Reduction to the Purchaser and the aggregate liability of the Supplier to the Purchaser, whether under the Contract, in tort or otherwise, shall not exceed the total Contract Price, provided that this limitation shall not apply to the cost of repairing or replacing defective equipment.</p>	Tender Condition Prevails
34	44 of 96	GCC- 44 COMPENSATION LIABILITY FOR ACTION NOT TAKEN UPON TERMINATION FOR DEFAULT	Kindly refer entire clause	Please mark clause 42.2 as not applicable.	Tender Condition Prevails
35	45 of 96	GCC- 47 CONTRACTOR TO INDEMNIFY THE OWNER	Kindly refer entire clause	<p>i. Add line "to the extent the contractor is at fault" in the beginning of the sentence.</p> <p>ii. The clause shall apply when the Contractor receives adequate notice, information and assistance from Buyer and has an opportunity to defend itself.</p> <p>iii. The Contractor's liability pursuant to this indemnification clause shall be limited in accordance with the terms of Article "Limitation of Liability."</p> <p>iv. The Owner shall likewise indemnify, defend and hold harmless the Contractor from and against any and all Losses arising out of any negligent act or omission of the Owner, its officers, agents, employees, contractors or assigns.</p>	Tender Condition Prevails
36	46 of 96	GCC- 52 Replacement of Defective parts and material	Kindly refer entire clause	<p>From 50.2 delete wordings "erection/installation".</p> <p>The replacement shall be as per the inco terms of original equipment.</p>	Tender Condition Prevails
37	48 of 96	60 Insurance	Kindly refer entire clause	<p>The Supplier shall obtain and maintain the following policies:</p> <p>(a) Transit insurance as per agreed inco terms shall be arranged by the Supplier</p> <p>(b) Workmen Compensation (with Employer's Liability) shall be in accordance with applicable laws.</p> <p>(c) General Public Liability shall be to the extent of the Purchase Order value per occurrence and in aggregate.</p> <p>However, we cannot waive subrogation right against customer and cannot name the Buyer as an additional insured.</p> <p>transit insurance as per agreed inco terms shall be arranged by the Supplier.</p>	Tender Condition Prevails
38	12 of 96	Section 1 /11.5	Traders / Dealers / Distributors / Stockist / Wholesalers are not entitled for exemption of Earnest Money Deposit (EMD) / Bid Security.	Bidder is udyam Registered Micro company is full filling all the requirement to get exemption on EMD	Tender Condition Prevails
39		Section IV	Regulator flange diameter	What is the pressure class of SOR mentioned regulator? Example is class 300 or PN 40	Class 300
40		Section IV	Regulator length	The regulator bidder will offer have different length (Face to face Distance). Hence requested to IGL please accept the regulator length provided by OEM in drawing or detail engineering	The bidder request is not acceptable. Tender Conditions Prevails.



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17435

SUPPLY OF FRS REGULATORS & SPARES WITH INSTALLATION AND COMMISSIONING

S.No.	Page	Section	Description	Bidder Queries	IGL Replies
41		Section IV	Service of regulator installation and commissioning	The regulator total quantity in SOR is 57 No. Bidders understand one regulator required one day for installation and commissioning. Hence, to total no of man day charge should be 57. Please confirm	This is a rate contract and commissioning of regulator is on number basis. Tender conditions Prevails.
42		Section IV		Please clarify the supply, installation and commissioning of FRS regulator will be a replacement of old regulator or new fresh installation.	Old regulator will be replaced by new one as per client requirement. Tender Condition Prevails.
43	65 of 96	Section V - 6.0	The regulators are meant for installation at various Client's premises, where space availability is the main constraint. The model shall be selected in such a way that it is compact and robust to suit the site conditions. Client has right to reject any model, proposed by the bidder, considering the size and shape of the regulator offered by them.	Bidder will submit the regulator drawing have dimension details. Once the drawing is approved rejection of proposed model shall not be applicable.	Tender conditions Prevails.
44	67 of 96	Section V - 8.2	Each regulator shall be accurately calibrated and tested by the Manufacturer at the normal working conditions specified in the attached data sheet. All test equipment used for testing shall have traceability to national standards.	No data sheet attached in tender document from page no 1 to 96. Please arrange if applicable	Data sheet enclosed. Refer Corrigendum-3
45	69 of 96	Section V - 11.1 (e)	Weight & measure approval certificate	Weight & measure approval certificate is for metrological instruments like EVC and meter. Pressure regulator is a safety device, factory test report (calibration report) shall be provided for review and approved	This Tender Clause stands deleted. Refer Corrigendum-3