



REPLY TO BIDDER'S PRE-BID QUERIES

**RATE CONTRACT FOR SUPPLY OF FLAME DETECTOR FOR COMPRESSOR
PACKAGES**

BID DOCUMENT NO. IGL/ET2/CP/CC18489

Owner: INDRAPRASTHA GAS LTD

Sl No	Page No.	Clause No.	Bidder's Query	IGL's Reply
1	63 of 87	Section-V SOW	Omniguard detectors come with self check with inbuilt source so testing gun is not required.	Tender Conditions Prevail
2	62 of 87	Section-V SOW Field of View- 120° cone of vision (or) Better.	we would like to clarify that a detector with a 100° horizontal × 80° vertical view angle is technically sufficient and compliant with the applicable norms, including OISD-STD-116	Tender Conditions Prevail