



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17712 Annual Rate Contract for Refurbishment & Upgradation of MRS Skids

S.No.	Page	Tender Clause No.	Description	Bidder Queries	IGL Replies
1	58 of 80	1.12 u/s SOW (Scope of Work)	SCOPE OF WORK FOR SERVICE PROVIDER It will be scope of service provider to obtain IRN from IGL appointed TPI after completion of refurbishment and then DCN from IGL which will be considered as handing over. PRS will be calculated accordingly.	Request you to please add few more suppliers for FILTER & PRV in the approved vendor list, as the given vendors have denied supply in small quantities in the last tender.	1st Criteria----The vendor who have supplied similar material/item with similar specifications to IGL and mentioned in IGL tender no-IGL/ET2/CP/CP17064 for procurement of MRS, then that vendor shall be considered as approved for supply. Further, vendors outside the 1st criteria can be accepted subjected to acceptance and approval of Past Track Record of the vendor. However, bidder shall estimate at their own risk & cost, in case of non-approval of proposed vendor. Tender Condition Prevails.
2	58 of 80	1.3 u/s SOW (Scope of Work)	SCOPE OF WORK FOR SERVICE PROVIDER Hydro-testing of skid.	Kindly clarify that how many times the hydro test pressure should be of working pressure.	Hydrotest pressure shall be 1.5 times of the design pressure (19 Bar(g)) and test duration shall be as per API 6D. Tender Condition Prevails.
3	58 of 80	1.7 u/s SOW (Scope of Work)	SCOPE OF WORK FOR SERVICE PROVIDER Skids to be refurbished by service provider within 06 weeks from date of handover of skid to service provider.	The 6 weeks time is a very difficult time frame to comply since procurement of items is subject to availability of material with approved supplier as per given list.	Tender Condition Prevails.
4	6 of 80 and 50 of 80	3.2 u/s IFB and 6.2 u/s SCC	DURATION OF CONTRACT & COMPLETION PERIOD 3.2 Completion Period: Skids to be refurbished by service provider within 06 weeks from date of handover of skid to service provider.	Completion Schedule: Skids to be refurbished by service provider within 06 weeks from date of handover of skid to service provider. - Considering the complete scope of work involved and the TPI activities, 6 weeks is unpractical period. We request you to please review and revise this as at least 12 weeks along with consideration to following changes in TPI role.	Tender Condition Prevails.
5	58 of 80	-	QAP	Please refer to QAP-Checklist-TPI scope indicated in tender. Request you to please consider following in this respect. a) Sr. no.: Welding / jointing...is internal activity of skid refurbishing contractor and TPI witness is not required. b) Sr. no. 4: TPI scope to be limited to final review of radiography report. c) Sr. no. 5 & 6: Replacement/Repair of Damaged/Non working equipment or part.....This activity is skid refurbishing contractor's responsibility and witness of TPI is not required. Picture records taken by contractor shall be reviewed by TPI. d) Sr. no. 11, 12 & 13: Hydro test of skid spools will be offered for TPI witness and complete skid hydro test offering is not a industry practice. Pneumatic test at 7 barg shall be offered for complete skid assembly.	Tender Condition Prevails.



REPLIES TO BIDDERS' QUERIES

Tender No. IGL/ET2/CP/CP17712 Annual Rate Contract for Refurbishment & Upgradation of MRS Skids

S.No.	Page	Tender Clause No.	Description	Bidder Queries	IGL Replies
6	-	-	-	We are fully equipped fabricator and have supplied our make filters for MRS. In case of requirement of change of filter, same shall be designed, manufactured, fabricated, tested by us.	<p>1st Criteria---The vendor who have supplied similar material/item with similar specifications to IGL and mentioned in IGL tender no-IGL/ET2/CP/CP17064 for procurement of MRS, then that vendor shall be considered as approved for supply.</p> <p>Further, vendors outside the 1st criteria can be accepted subjected to acceptance and approval of Past Track Record of the vendor.</p> <p>However, bidder shall estimate at their own risk & cost, in case of non-approval of proposed vendor. Tender Condition Prevails.</p>
7	-	-	-	For items such as Gauges, valves etc. please provide approved vendor list if any.	<p>1st Criteria---The vendor who have supplied similar material/item with similar specifications to IGL and mentioned in IGL tender no-IGL/ET2/CP/CP17064 for procurement of MRS, then that vendor shall be considered as approved for supply.</p> <p>Further, vendors outside the 1st criteria can be accepted subjected to acceptance and approval of Past Track Record of the vendor.</p> <p>However, bidder shall estimate at their own risk & cost, in case of non-approval of proposed vendor. Tender Condition Prevails.</p>
8	-	-	-	Please provide following process parameters of existing skids as well process parameters to be considered for upgradation of the skids. Required process parameters, (a) Inlet Pressure (b) Outlet pressure (c) Flow in SCMh (d) Inlet / outlet flange connection for skid and existing pipe size before & after filtration within skid.	<p>The process parameters required for skid after upgradation are as follows: (a) Inlet pressure range bar(g) Min/max=3 to 4 bar (b) Outlet pressure range bar(g) Min/max=1 to 2 bar (c) Flow (SCMH) Min/Max=50 to 450 (d) Design pressure bar(g)=19 (e) Allowable Pressure drop across skid Bar(g) Max=1.5 (Service provider shall consider the pressure drop across the skid as per the requirement of outlet pressure. Given pressure drop is maximum). (f) Temp (design) Deg C= -29 to 65 (g) The maximum permitted velocity shall be 20 m/s at Inlet & outlet of skid and 30m/s velocity inside the skid for filtered natural gas.</p> <p>The process parameter for existing skid is same as above except the flow (SCMH) Min/Max=50/250 Tender Condition Prevails</p>