



INDRAPRASTHA GAS LIMITED
IGL Bhawan, 4, Community Center,
Sector 9, R.K.Puram, New Delhi-110022
Email: prateek.shrivastava@igl.co.in/ gaurav.agrawal1@igl.co.in/ dnagar@igl.co.in
Phone: +91 11 4607 4651

TENDER DOCUMENT NO.IGL/ET2/CP/CM18044
Supply, Installation, Testing and Commissioning of Fixed Gas Detection System for FRS

REPLY TO PREBID QUERIES

Sr No.	Section	Tender Clause	Page No.	Description	Bidder Query	IGL Remarks
1	V	Scope of Work Clause no. 2.15	63	ATEX/ IECEx for Zone 1	We would like to know if you need complete Gas Detector ATEX/ IECEx Zone 1 or only the transmitter Enclosure to be ATEX tested & Certified? Being the application is for Combustible Gases & the Sensor housing in which Sensor is housed need supply. In our opinion only transmitter enclosure being ATEX tested & Certified will not achieve the required hazardous area safety.	As per scope of work, complete Gas Detector unit should be ATEX/ IECEx Zone 1 certified

Note:

1. Please note that only the clarifications of the queries received from the bidder's are replied in this corrigendum, under reply to bidder's Query.
2. All other terms & conditions of tender document remain unaltered.
3. Bidders are requested to visit IGL website / IGL's tendering website <https://petroleum.ewizard.com> regularly for further announcement
4. Please submit the signed and stamped copy of this corrigendum along with your offer.