

## INDRAPRASTHA GAS LIMITED



TENDER DOCUMENT NO.IGL/ET2/CP/CM18548

O&amp;M SERVICES FOR FIREFIGHTING SYSTEM AND FIRE DETECTION SYSTEM INSTALLED AT IGL BHAWAN &amp; IP STORE BUILDING.

## REPLY TO PREBID QUERIES

S.NO	Section	Tender Clause.	Page No.	Particulars	Description	Bidder Query	IGL Reply
1	V	SCOPE OF WORK	57-63	-	-	Do the bidders need OEM authorisation of M/S Siemens for this project in order to participate in this tender ?	For maintenance and upkeep of the automatic addressable type fire detection system so that the system can detect any fire incident at early stage, it crucial that the vendor has authorisation from system's OEM M/S Siemens for technical support and early resolution of any problem/issue countered by the system. The authorization certificate from M/S Siemens for this project needs to be submitted along with the technical bid.