

Reply to Pre-bid Queries

Tender No.:IGL/ET2/CP/CC17463

SUPPLY, INSTALLATION, COMMISSIONING AND COMPREHENSIVE MAINTENANCE OF LNG DISPENSER

Sr. No.	Clause No.	Page No.	Subject Description	Bidder's Queries	Reply / Clarifications
1	Section V Scope Of Work (2.0.Definitions)	70 of 108	The inspection agency to be appointed by Client / Client Approved TPIA	The LNG Dispenser is Type Approved equipment, and Bureau Veritas is the TPIA inspection agency for the bidder.	TPIA to be finalised at the time of detailed engineering
2	Section V Scope Of Work (3.0.General Notes)	71 of 108	Boil off Gas data with calculation	Bidder scope is limited to the supply of LNG Dispenser, which don't store any liquid. Hence, this provision is not applicable.	Noted
3	Section V Scope Of Work (4.0.Scope of Supply)	71 of 108	LNG dispensing nozzle: Size 1", Type JC Carter nozzle	Bidder request Owner to consider REGO make Nozzle as this is internationally recognized.	Bidder may supply other make LNG dispensing nozzle subject to submission of PTR documents & approval by IGL. Also, bidder has to ensure compatibility or provide suitable arrangement along with nozzle to fill LNG vehicles with any type of recepticle. Filling nozzle & arrangement shall comply to Indian/ International safety and operational standards
4	Section V Scope Of Work (4.0.Scope of Supply)	71 of 108	Integration to card payment and printing facility	Bidder request Owner to consider Modbus communication instead of Integration to card payment and printing facility.	Bidder has to provide all the required parameters over the modbus communication for the integration with card payment & printing facility. Also, necessary support to be provided by succesful bidder to IGL for integration of the same
5	Section V Scope Of Work (4.0.Scope of Supply)	71 of 108	Inlet and return Control valve	Bidder request Owner to consider On-Off Valve instead of Inlet and return control valve.	Tender Condition Prevails
6	Section V Scope Of Work (5.0.Refernce Documents)	71 of 108	Reference Documents	Bidder understands that Major applicable codes are provided as a guideline or for reference; and compliance shall be as applicable in India i.e. Bidder have consider only latest edition of, LNG Dispenser: BS EN ISO16924. Cryogenic Hose: ISO 21012 Layout: Static and Mobile Pressure Vessel (SMPV) Rules (Unfired) as well as Gas cylinder rules.	Tender Condition Prevails
7	Section V Scope Of Work (6.0.Design and Construction)	74 to 78	Design and Construction Requirements	Bidder request Owner to accept LNG Dispenser is type approved from PESO and Weights & Measuring body. Any specific requirement cannot be implemented.	Tender Condition Prevails

Reply to Pre-bid Queries

Tender No.:IGL/ET2/CP/CC17463

SUPPLY, INSTALLATION, COMMISSIONING AND COMPREHENSIVE MAINTENANCE OF LNG DISPENSER

Sr. No.	Clause No.	Page No.	Subject Description	Bidder's Queries	Reply / Clarifications
8	Section V Scope Of Work (8.0.Surface Preparation and Painting)	78 to 79	Surface Preparation and Painting	We shall supply dispenser enclosure with powder coated.	Noted. To be discussed during detailed engineering
9	Notice for Invitation for Bid (IFB) Clause No.3	7 of 108	Delivery Schedule	Bidder understand that contract duration for supply of dispenser is 06 (Six) months from PO/LOA. Kindly Confirm.	Delivery shall be made within 12 weeks from the date of issuance of LOA/Notification of Award. Contract validity of Supply part is 6 months. Refer clause no. 3.0 of IFB which is self explanatory.
10	Special Conditions of Contract (SCC) Clause No.10.0	57 of 108	Construction water and power supply	Bidder understand that water and power required during testing and commissioning of Dispenser at Owner premises will be provided by Owner.	Tender Condition Prevails
11	General Conditions of Contract (GCC) Clause No.33.0	41 of 108	Termination for Owner Convenience	Bidder requests Owner to modify the termination for owner's convenience as below: "In case of non-performance of Bidder / Contractor for defined tender scope, Owner may terminate the contract within 30 days prior notice."	Tender Condition Prevails
12	Special Conditions of Contract (SCC) Clause No.34.4	68 of 108	Statutory Approval Any change/ addition required to be made to meet the requirements of the statutory authorities shall be carried out by the Contractor without additional cost to Owner.	Bidder requests Owner/PMC to redefine the statement as below: "We (Bidder) hereby confirm that we will comply with all pre define statutory requirements in tender without price implication. However, In case of any change in statutory requirements post bid submission, the same will be comply with mutually agreed price addition between bidder/Contractor and IGL".	Tender Condition Prevails
13	Special Conditions of Contract (SCC) Clause No.15.1	58 of 108	Contract Performance Bank Guarantee (CPBG) For Supply, installation & commissioning and Performance Acceptance Test: equivalent to 10% of respective Purchase Order value.	Bidder request Owner to consider CPBG @ 3% of total contract value.	Tender Condition Prevails

Reply to Pre-bid Queries

Tender No.:IGL/ET2/CP/CC17463

SUPPLY, INSTALLATION, COMMISSIONING AND COMPREHENSIVE MAINTENANCE OF LNG DISPENSER

Sr. No.	Clause No.	Page No.	Subject Description	Bidder's Queries	Reply / Clarifications
14	Forms & Formats	91,93 & 102 of 108	Format for certificate from Statutory Auditor / Chartered Engineer as per Form-3 & 4 along with supporting documents	For Technical Criteria of BEC: Bidder understand that all documentation submitted in support of the BEC's technical requirements must be duly certified/attested by Chartered Engineer / Statutory Auditor with legible stamp. Kindly confirm.	Format for certificate from Statutory Auditor / Chartered Engineer /CA as per Form-3 & 4 or wherever specifically mentioned. Supporting documents have to be self-certified by bidder